

Cisterns

Includes: (1) 24"ID x 12" high Polylok access, 6" PVC fill stack and cap , 1¼" PVC Foot Valve

For all cisterns, backfill must be complete before filling with liquid. Allow cistern sealants a minimum of 24 hours to settle before filling above the joint. 18,150L (4,000gal) or larger cisterns dig size must be a minimum of 271" long x 174" wide as they must be assembled on-site. The exterior of the tank must remain completely dry during the entire assembly process. Any moisture present will not allow the membrane to adhere.

Ontario Agra will not be responsible for any defects resulting from moisture presence during assembly and have the right to refuse to apply membrane due to site conditions.

Total Capacity		Dimensions in Inches			Est. Weight Tons	
Litres	Imp. Gallons	L	W	H		
4,500	1,000	120	75	55	+14" to top of lid	5.2
9,000	2,000	168	90	66	+14" to top of lid	10.3
14,000	3,000	179	102	66	+14" to top of lid	14.2
18,150	4,000	199	102	73	+14" to top of lid	
22,700	5,000	199	102	88	+14" to top of lid	
27,250	6,000	199	102	104	+14" to top of lid	20

Holding Tanks

Includes: (1) 20"ID Polylok Access

1,000	240	50	64	36	28	2
2,100	470	60	54	63	53	2.6
3,900	860	86	64	70	59	4
4,500	1,000	120	54	69	59	5.2
6,605	1,450	126	84	63	53	7.2
9,000	2,000	168	90	66	54	10.3
14,000	3,000	179	102	66	56 ¼	14.2
18,150	4,000	199	102	73	60 ¾	
22,700	5,000	199	102	88	76 ¼	
27,250	6,000	199	102	104	92	20